



57121 LIVORNO (ITALY)
VIA P. PISANA , 470
TEL. (0586 400.490 - FAX 420398
C.C.I.A. 77476 - REG. DOC. TRIB. LI. 11146
C.F. e P. IVA 00805640497

YEAR 2024	MONTH 01	DAY 18	TYPE AND NAME OF VESSEL/UNIT M/N MOBY FANTASY	CERTIFICATE N° 9173.010.01/24
COVERING: CO2 PILOT CYLINDERS OF EMERG.GEN.ROOM SYSTEM				PLANT N°:

Description of working code (Performed/Recommended):

1= Inspected/contents checked by level	5= Hydrottested	9= New cylinder
2= Inspected/contents checked by weight	6= Valve renewed	10= Rejected
3= Inspected/contents checked by pressure	7= Valve repaired	*= Recommendations
4= Recharged	8= External maintenance	(applicable nos. to be added: 4 - 8

Type of Gas Cylinder	Name of Manufacturer	Cylinder Serial Numbers	Last Hydrost. Test Date	Tare Weight Kg./Lbs.	Gross Weight Kg./Lbs.	Cyl.vol. ltr./CuFt. or Capacity Kg./Lbs.	Pressure Reading Bar/Psi	Temp. °C/°F	Performed/Recommended
CO2	SSF	20344094	9/2020	4,39 Kg.	5,89 Kg.	1,5 Kg.	----	----	2
CO2	SSF	20344095	9/2020	4,56 Kg.	6,06 Kg.	1,5 Kg.	----	----	2
CO2	SSF	20344006	9/2020	4,55 Kg.	6,05 Kg.	1,5 Kg.	----	----	2
CO2	SSF	20344010	9/2020	4,62 Kg.	6,12 Kg.	1,5 Kg.	----	----	2

Ship's signature and stamp

Surveyor's signature



Inspector's signature