



antincendio
fire-fighting

S.R.L.

57121 LIVORNO (ITALY)

VIA P. PISANA , 470
TEL. (0586 400.490 - FAX 420398

C.C.I.A. 77476 - REG. DOC. TRIB. LI. 11146

C.F. e P. IVA 00805640497

INSPECTION REPORT

FIRE EXTINGUISHERS



CERTIFICATE N°:
9173.010.01/24

Ship's name : **M/N MOBY FANTASY**

Owner Name : **MOBY S.P.A.**

Place and data : **LIVORNO – 18/01/2024**

N°	TYPE*	CAP. Kos./ltr	FIRE EXTINGUISHERS					DESCRIPTION OF WORK**
			ON BOARD	CHECKED	CONDAMNED	REPLACED BY NEW	TOTAL	
01	CO2	5 Kg.	23	23	----	----	23	F.M
02	CO2	20 Kg.	2	2	----	----	2	F.M
03	DP.PO.	6 Kg.	280	280	4	----	276	B.G.M
04	DP.PP.	2 Kg.	8	8	----	----	8	D.M
05	DP.PP.	6 Kg.	----	----	----	4	4	D.M.-NEW
06	DP.WP.	25 Kg.	2	2	----	----	2	D.F1.M
07	F.WO.	50 ltr.	3	3	----	----	3	C.G.F1.M
08	F.PP.	9 ltr.	2	2	----	----	2	E.J.M

Specification of types:

DP = DRY POWDER

W = WATER

CO2 = CO2

F = FOAM

H = HALON

SA = SODA ACID

PO = PORTABLE-OPEN

PP = PORTABLE-PRESSURE OPERATED

WO = ON WHEELS-OPEN

WP = ON WHEELS-PRESSURE OPERATED

Ship's signature and stamp

Surveyor's signature



Inspector's signature



57121 LIVORNO (ITALY)
VIA P. PISANA , 470
TEL. (05867 400.490 - FAX 420398
C.C.I.A. 77476 - REG. DOC. TRIB. LI. 11146
C.F. e P. IVA 00805640497

INSPECTION REPORT

FIRE EXTINGUISHERS



CERTIFICATE N°:
9173.010.01/24

DESCRIPTION OF WORK

- A. Inspection of Water extinguishers (PORTABLE OPEN) :**
Body of extinguisher and transfer cleaned and inspected. Discharge head cleaned, inspected and made easily movable. Hose and discharge nozzle removed, blown clear and inspected Water quality and level inspected. Rising tube checked. Cartridge check weighted and body of extinguisher internally inspected. Extinguisher sealed with new date label and replaced.
- B. Inspection of Powder extinguishers (PORTABLE OPEN) :**
Body of extinguisher and transfer cleaned and inspected. Discharge head cleaned, inspected and made easily movable. Hose and discharge nozzle removed, blown clear and inspected Dry powder inspected for clogging and caking. Diptube inspected and blown clear. Body of extinguisher internally inspected. Cartridge check weighted Extinguisher sealed with new date label and replaced.
- C. Inspection of Foam extinguishers (PORTABLE OPEN) :**
Body of extinguisher and transfer cleaned and inspected. Discharge head cleaned, inspected and made easily movable. Hose and discharge nozzle removed, blown clear and inspected. Foam level inspected. Rising tube checked. Cartridge check weighted and body of extinguisher internally inspected. Extinguisher sealed with new date label and replaced.
- D. Inspection of power extinguishers (PORTABLE PRESSURE OPERATED):**
Body of extinguisher and transfer cleaned and inspected. Pressure checked. Discharge mechanism removed, inspected, made easily movable, and refitted. Discharge hose and nozzle removed, blown clear, inspected and refitted. Extinguisher sealed with new date label and replaced.
- E. Inspection of foam extinguishers (PORTABLE PRESSURE OPERATED):**
Body of extinguisher and transfer cleaned and inspected. Pressure and contents of extinguisher inspected. Discharge head cleaned, inspected and made easily movable, washer inspected. Discharge nozzle and hose cleaned and inspected. Extinguisher sealed with new date label and replaced.
- F. Inspection of CO2 extinguishers (PORTABLE PRESSURE OPERATED):**
Body of extinguisher and transfer cleaned. Hose and snow-horn removed, blown clear, inspected and refitted. Discharge valve inspected. Extinguisher checkweighted and last hydrotest date checked. Extinguisher sealed with new date label and replaced.
- F1. FIRE EXTINGUISHERS ON WEELS:**
Wheels and lifting gear on the extinguisher checked. Otherwise same procedure as stated above for the various portable types.
- G. Spare Cartridges:**
Cartridge collected, check weighted, inspected and replaced.
- H. Hydrotest of extinguishers:**
Extinguisher pressure tested as per requirements duly stamped on the body.
- I. Cartridge refilled to correct pressure.**
- J. Extinguisher refilled with correct quantity.**
- K. Parts replaced (see specification).**
- M. Ship's Safety plan and extinguishers marked.**